

EASTERN INDIA POWERTECH LTD.
AIR QUALITY MONITORING AT BANSKANDI POWER PLANT


Date of testing: - 21-09-2012

Test results

S. L. No	Parameters	Ambient air samples		
		Near gate	Near Pump House	Near switch Yard
1.	S.P.M.	68	70	72
2.	SO ₂	Undetectable	Undetectable	Undetectable
3.	NOX	8.4	24.4	16.50

1. All results are expressed in $\mu\text{gm}/\text{m}^3$
2. All samples are for 24 hours average


Analyst


Plant In-Charge


EASTERN INDIA POWERTECH LTD.
NOISE LEVEL MONITORING AT BANSKANDI POWER PLANT

Date:-24-09-2012

Test results

- | | |
|-----------------|----------|
| 1. Control Room | 56-60 db |
| 2. Office Room | 51-53 db |
| 3. Workers Room | 68-70 db |
| 4. Pump House | 75-77 db |


Monitored By


Plant In-charge